CORRIGENDUM-I

Ref: Tender Enquiry No.- TPWODL/NP/O/SU/025, Date:26.07.2021. Inviting reference to the above, the prospective bidders may note the following change/ modification to relevant provisions of our Tender Notice & Tender Specifications.

Ref. Clause No./ Description of Parameters	Existing Tender Terms		Amended as				
Electronic Reference Standard Meter for testing of HT Meters							
Clause No3 of Technical Specification/SYSTEM TECHNICAL DATA	Additional		Separate Clamp on CT Probe along with Direct Probe (-/1A & - /5A) with internal CT rating 10mA to 10A and Rating of Clamp on CT= Min. 50mA to 10A is required.				
Clause No7 of	Measurement	Accuracy	Measurement	Accuracy			
Technical	Mode	Class	Mode	Class			
Specification/ACCURACY REQUIREMENT	Direct Mode (1 A and 5 A)	0.2s	Direct Mode (1 A and 5 A)	0.2s			
	For the certification accuracy of test equipment, a LED pulse output shall be provided on it.		Clamp on CT Mode	0.2s			
			For the certification accuracy of test equipment, a LED pulse output shall be provided on it.				
SI No3 of GTP	Accuracy Class		Accuracy Class				
	1. Direct Mode: 0.2		1. Direct Mode: 0.2s				
			2. Clamp on Mode: 0.2s				
Sl. No 9 of GTP	Memory - Maximum 175 test		Memory- Capable to store				
	results		minimum 3000 numbers of test result.				
	Newly added		For direct mode: current				
			selection is either through				
			software or through separate				
			terminals or both, either case is				
			acceptable.				
Electronic Reference Stan	dard Meter for testi	ng of Whole Curr					
Clause No 7 of	Measurement	Accuracy	Measurement	Accuracy			
Technical Specification	Mode	Class	Mode	, Class			
	Direct Mode (1	0.2s	Direct Mode (1	0.2s			
	A and 5 A)		A and 5 A)				
	Clamp on CT	0.5s	Clamp on CT	0.2s			
	Mode		Mode				
	For the certification accuracy of		For the certification accuracy of test				
	test equipment, a LED pulse output		equipment, a LED pulse output shall				

	shall be provided on it.	be provided on it.	
SI. No3 of GTP	Accuracy Class	Accuracy Class	
	1. Direct Mode: 0.2	1. Direct Mode: 0.2s	
	2. Clamp on Mode: 0.5	2. Clamp on Mode: 0.2s	
Sl. No4 of GTP	Current rating of Clamp On CT	Current rating of	
		Clamp On CT- 500mAmps or 1A to	
		400/800Amp.	
		Internal CT- 10mAmp to 10Amp.	
Sl. No10 of GTP	Memory - Maximum 175 test	Memory- Capable to store	
	results	minimum 5000 numbers of test	
		result.	
	Newly added	For direct mode: current	
		selection is either through	
		software or through separate	
		terminals or both, either case is acceptable.	

Also, Clause NO.- 1.3. Calendar of Events is revised as mentioned below:-

Sl. No.	Calendar of Event	Existing Schedule	Revised Schedule	
1.	Date by which interested and eligible vendor to pay tender fee and confirm participation in accordance with "Procedure for participation in tender".	06.08.2021 15:00 Hours	13.08.2021 15:00 Hours	
2.	Last Date of receipt of pre-bid queries, if any	13.08.2021 15:00 Hours	20.08.2021 15:00 Hours	
3.	Last Date of Posting Consolidated replies to all the pre-bid queries as received	20.08.2021 15:00 Hours	27.08.2021 15:00 Hours	
4.	Last date and time of receipt of Bids	27.08.2021 15:00 Hours	03.09.2021 15:00 Hours	

All other terms and conditions of the above tender will remains unaltered.