

Consolidated replies to the Prebid queries - Technical

Tender No.: TPCODL / CCG / 24-25 / 1000001334

Sl. No.	Please specify the Page No. of the reference Tender NIT Document.	Detailed Reference to the Tender NIT Document. Please specify Clause No.	Description as per Bid Document	Query / Clarification submitted by Bidder.	CCG Response
A	B	C	D	E	F
1	41	4.0 General Technical Requirements - Lightning Impulse withstand of XLPE Layer	Not Applicable as per BS-50397 P-1 - If required, kindly let us know the reference standard.	Not Applicable as per BS-50397 P-1 - If required, kindly let us know the reference standard.	Noted.
2	45	8.0 Type Test Certificates	Required of CPRI/ ERDA	Required of CPRI, ERDA & <b>NABL accredited Laboratory</b>	Type Test Reports to be furnished from <b>CPRI/ERDA</b> only.
3	47	13.0 Tender Sample	Bidder shall submit sample of material during submission of Bids	It is not feasible to submit sample alongwith Bid	Please submit the sample after placing bid.
4	57	7.2 Routine Test	1. Visual Examination and dimension check test 2. High Voltage Test 3. Spark Test	Only High Voltage Test, Conductor Resistance Test & Spark Test shall be conducted under Routine Test	Noted.