



Corrigendum No. – 2

Dated: 03.07.2026

Tender No.- TPWODL/AK/O/SER/ 2500001210

Tender Subject- Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 kV Network Maintenance and Operational Assistance of 33/11 kV Sub-Stations of TPWODL for 3 years.

Following revised documents are enclosed and to be as followed for bid submission:

1. Revised 11 KV AMC and 33 KV AMC & PSS Operation Resource Deployment list.
2. Revised Price Bid Format attached separately, to be followed for Price Bid Submission.
3. All other terms and conditions of the above tender shall remain unaltered.

By Order

Chief- (Technical Services, Contracts & Stores)

FORMAT F.1
Format for Query / Clarification / Deviation (QCD)

Tender No: TPWODL/AK/O/SER/2500001210

Package Name: Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 kV Network Maintenance and Operational Assistance of 33/11 kV Sub-Stations of TPWODL for 3 years.

Note : The said format to be used only for any Pre-bid Query / Clarification/ Deviation on any of the Tender documents

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPWODL Response
1	2	3	4	5
1	11 KV AMC Tools and tackles Sr. No. 2	HDPE Safety helmet with chin strap and ratchet type for adjustment. (E class- Electrical grade Safety Helmet)	Heapro make has been deleted. What about the buffer stock we are having with us?	Buffer stock shall be declared by existing BA if they are successful as per the new Contract. These buffer stocks shall be duly verified & approved by DISCOM Safety Head. New Purchase of PPEs shall be procured as per the detailed MAke shared in RFP/ tender document.
2	11 KV AMC Tools and tackles Sr. No. 3	Full body harness non padded (Safety belt with Double Lanyard with Shock-Absorber & Pole Grab Arrestor) and adjustable Work positioning belt	Heapro make has been deleted. What about the buffer stock we are having with us?	Buffer stock shall be declared by existing BA if they are successful as per the new Contract. These buffer stocks shall be duly verified & approved by DISCOM Safety Head. New Purchase of PPEs shall be procured as per the detailed MAke shared in RFP/ tender document.
3	11 KV AMC Tools and tackles Sr. No. 4 & 5	500V Electrical Safety Gloves – Composite type Soft electrical gloves as per size of individual . (EN +ISI Mark on gloves)Class-02with swet absorbing cotton gloves	Item no 4 & 5 of same class 02 where as Voltage is different.	Please refer the revised T & P list as per the RFP/ tender document.
4	11 KV AMC Tools and tackles Sr. No. 6	Arc face visor with safety helmet. 8cal/ cm square	Arc Face visor costs about 6/7 thousand per piece and no Indian company is manufacturing. Where as upto 11 Kv no one works in the Arc zone. Earlier approved make may be allowed as full face visor.	Face Visor wiser as an attachment for Safety Helmet
5	11 KV AMC Tools and tackles Sr. No. 7	High visibility Cotton bledned T-shirt with Reflective stips for all employees.	It is to confirm that the T Shirt mentioned will replace the uniform shirt and which colour of T Shirt will be	T Shirt has to be mandatorily provided by BA to each employee as per the details shared in T & P list as per the tender document.
6	11 KV AMC Tools and tackles Sr. No. 11	Welding PPE's (FR Apron, Neck Hood, Hand Sleeve, Shoe Guard, Nose Mask & leather 14" hand Gloves, wlding helmet Dark glass with Face Shiled, etc.)	Continuos welding work is not being carried out and for minor work Apron,welding face shield and welding gloves are sufficient.	To be provided as mentioned in RFP.
7	11 KV AMC Tools and tackles Sr. No. 14 & 15	FRP Ladder 9 Mtrs. (2 Fold) FRP Ladder 12 Mtrs. (3 Fold)	APS make has been deleted. What about the buffer stock we are having with us?	Buffer stock shall be declared by existing BA if they are successful as per the new Contract. These buffer stocks shall be duly verified & approved by DISCOM Safety Head. New Purchase of PPEs shall be procured as per the detailed MAke shared in RFP/ tender document.
8	11 KV AMC Tools and tackles Sr. No. 18	Ring spanner set with Double Insulated Ring spanner set	You required double insulated tool which will abnormally increase the cost. A single wrench is costing three times the cost of a normal set. What about the buffer stock we are having and the tools which are not expired.	Please refer the revised T & P list as per the RFP/ tender document.
9	11 KV AMC Tools and tackles Sr. No. 21	C Headed spanner set with Double Insulated Ring spanner set	Description not clear.	Please refer the revised T & P list as per the RFP/ tender document.
10	11 KV AMC Tools and tackles Sr. No. 22 & 23	Hammer 0.5-2 Kg with Fibre Handle Hammer 5 Kg with with Fibre Handle	Fibre handles will increase the cost and replacement will be difficult as material is not easily available in Odisha.	Please refer the revised T & P list as per the RFP/ tender document.
11	11 KV AMC Tools and tackles Sr. No. 25	Insulated Pliers (Reputed Make) with double insulated	Pliers we are using of reputed make with its original insulation as per standard and being used with appropriate safety gloves. Then why double insulated ? Again cost increase.	Please refer the revised T & P list as per the RFP/ tender document.
12	11 KV AMC Tools and tackles Sr. No. 27	Adjustable Spanner set with double insulated	You required double insulated tool which will increase rate by three times and what about the buffer stock we are having and the tools which are not expired.	Please refer the revised T & P list as per the RFP/ tender document.
13	11 KV AMC Tools and tackles Sr. No. 28	Monkey Pliers with double insulated	You required double insulated tool which will increase rate by three times and what about the buffer stock we are having and the tools which are not expired.	Please refer the revised T & P list as per the RFP/ tender document.
14	11 KV AMC Tools and tackles Sr. No. 32	Polypopylene Rope 24 MM - 200mtr	AMC vehcle is the vehicle for 24 Hrs. Please cofirm	Polypopylene Rope 24 MM - 200mtr has been revsied to 20 Mtr. 20 Mtr / (1 Per FCC + 4 Per AMC Vehicle)
15	11 KV AMC Tools and tackles Sr. No. 33	Polypropylene Rope 8 MM -	There are six type of vehicle kindly confirm for which vehicle we have to provide where you have mentioned per vehicle.	20 Mtr / Vehicle
16	11 KV AMC Tools and tackles Sr. No. 36	Screw Driver set with Double Insulated Screw Driver set	Again double insulated. Screw Drivers we are using of reputed make with proper insulated sleeve.	Please refer the revised T & P list as per the RFP/ tender document.

FORMAT F.1**Format for Query / Clarification / Deviation (QCD)**

Tender No: TPWODL/AK/O/SER/2500001210

Package Name: Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 kV Network Maintenance and Operational Assistance of 33/11 kV Sub-Stations of TPWODL for 3 years.

Note : The said format to be used only for any Pre-bid Query / Clarification/ Deviation on any of the Tender documents

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPWODL Response
1	2	3	4	5
17	11 KV AMC Tools and tackles Sr. No. 37	Nose Pliers with Double Insulated Screw Driver set	Pliers we are using of reputed make with its original insulation as per standard and being used with appropriate safety gloves. Then why double insulated ? Again cost increse.	Please refer the revised T & P list as per the RFP/ tender document.
18	11 KV AMC Tools and tackles Sr. No. 59 & 60	Discharge Rod suitable with 15 m long minimum 16 mm sq. (for AMC Vehicle) & 16 mm. sq. (for FCC) insulated Copper wire & 7.5 m operating stick. Universal Rod Stick (For neon tester)	APS make has been deleted. What about the buffer stock we are having with us?	Buffer stock shall be declared by existing BA if they are successful as per the new Contract. These buffer stocks shall be duly verified & approved by DISCOM Safety Head. New Purchase of PPEs shall be procured as per the detailed MAKE shared in RFP/ tender document.
19	11 KV AMC Tools and tackles Sr. No. 63	Fuse wire of different ratings	As per existing AMC tender, TPWODL is providing fuse wire as free issue material. If it is now in scope of BA kindly provide the specifications of fuse wire to be supplied. The qty. as per tender is 0.5 KG per LM per Quarter is comprising of all sizes of fuse wire you required.	Fuse wire availability is in the scope of TPWODL
20	11 KV AMC Tools and tackles Sr. No. 84 & 85	Digital earth resistance tester with suitable probes (Make- Rishabh) Digital Insulation Resistance tester (500V-5000V) with suitable probes (Make- Rishabh)	WACO make may please be allowed	Waco make is allowed. Please refer the revised T & P list as per the RFP/ tender document.
21	11 KV AMC Tools and tackles Sr. No. 90	Pressure Torque wrench manual	Please confirm Capacity?	The same shall be provided of withstand capacity of 100 ft-lbs
22	33 KV Tools TPWODL Sr. No. 30	Torch/Emergency lights-Re-Chargeable Torch (Philips Blaze Multi-functional Long Range Rechargeable Emergency Light),500watt	It is available only online in 15 watt	Please refer the revised T & P list as per the RFP/ tender document.
23	33 KV Tools TPWODL Sr. No. 46	FRP ladder with Temporary set up with life (14MTR) ,3 fold	What is temporary set up with life & where & how it can be used?	Please refer the revised T & P list as per the RFP/ tender document.
24	33 KV Tools TPWODL Sr. No. 71	Portable battery charger (Unit) One per division	Specifications?	Input-230V AC, Out Put- 12V DC to 48V DC with step of 12 V DC, Additional fine tuning option in step of 2V, Current capacity 20 Amp in 48V Tape, of any Reputed make.
25	33 KV Tools TPWODL Sr. No. 84 to 94	Sr. No. 84 to 94	These tools are being used for project work and not for AMC. You are requested to delete these tools from tool list as it will increase the cost.	For safe Conductor Stringing (learning from LWDC) - Suggested Additional tools and tackles by all DISCOM and to be ensured by BA.
26	SOW_SLA-TPWODL_11 kV AMC Page no. 2	c. 11 kV Feeder Maintenance Activities:	Regarding trimming of trees TPWODL will provide the required permission to trim the tree from NGT/forest Deptt. Etc. and for dumping of the cut pieces to the dumping yard of civic body. Note: the BA shall deploy specified manpower for cutting of big trees (there should be provision in the manpower list to maintain their wages and statutory legal compliances	Clearance is in TPWODL scope. Trimming part is in the scope of BA.
27	SOW_SLA-TPWODL_11 kV AMC Page no. 3	XV. Thermo-scanning of Network.	The thermoscanning device will be provided by TPWODL?	Yes TPWODL will Provide thermoscanning device.
28	SOW_SLA-TPWODL_11 kV AMC Page no. 5	Other equipment in DSS: IV. KIT KAT Fuse: Repair of KIT KAT Fuse. Replacement or installation of new KIT KAT Fuse as instructed by EIC. (KIT KAT Fuse will be provided by TPWODL).	Who will provide the fuse wire?	Fuse wire will be provided by TPWODL.
29	SOW_SLA-TPWODL_11 kV AMC Page no. 22	j) BA may have to establish Fuse call centre / Bidyut Sewa Kendra (BSK) by taking Premises on rent for running Fuse call Camp in the TPWODL area as per requirement & directions from Head Distribution Services). The Premises shall be adequate for minimum sitting capacity of 6 persons along with proper & safe storage of T&P items,	TPWODL will provide the rent of 1500/- for rural and 2500/- for urban are FCC fuse call centre. Please explain what about of Electricity , Furniture and drinking water in such centres?	FCC maintenance shall be the scope of BA only. All the requirement as mentioned in the tender shall be provided by BA without any additional cost.
30	33kV AMC SOW & SLA for Tender Page no. 6	3. Thermography of the lines/feeders to be done for identifying any abnormal temp. rise or any hot spot inline/feeders. Detailed Thermography reports to be submitted to TPWODL engineer-in-charge and Corp. Team without fail.	Regarding Thermography, this is to be carried out by specialised person. Only normal Thermoscanner for identifying temprature of Hot Spot can only be done by AMC staff. Please clarlify	Only normal Thermoscanner for identifying temprature of Hot Spot will be done by AMC staff

FORMAT F.1**Format for Query / Clarification / Deviation (QCD)**

Tender No: TPWODL/AK/O/SER/2500001210

Package Name: Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 kV Network Maintenance and Operational Assistance of 33/11 kV Sub-Stations of TPWODL for 3 years.

Note : The said format to be used only for any Pre-bid Query / Clarification/ Deviation on any of the Tender documents

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPWODL Response
1	2	3	4	5
31	General		Time to time announcement through Loud Speaker for public regarding shut down, maintenance etc. will be in whose scope?	It will be in Scope of BA with available vehicle in respective section.
32	11 KV AMC Tools and tackles Sr. No.16	FRP Ladder up to 7 Mtrs. (Collapsible Ladder)	Only these ladder are imported from China, no approved vendor mentioned in the tender is manufacturing such ladders. As per our experience in TPSODL the damage rate of the ladder is very high and to replace these ladders it takes much time due to non availability with the local vendors and there spares are not easily available. Pl. look into the matter and suggest accordingly, as it is introduced for the first time in TPWODL.	Tender Terms & conditions shall prevail.
33	11KV SOW (Page :9,Point No :2)	Replacement of tilted/broken poles and accessories along with painting of GIS number, Transportation of pole (from any site to work location within same division) will be in scope of BA. All these replacement activities shall be done without any additional cost implication to TPWODL	In the case of a newly allocated division, the BA may not have access the data regarding the number and condition of tilted or broken poles requiring replacement during the contract period. Since pole replacement involves significant expenditure towards materials, transportation, equipment, and manpower. Kindly clarify the same.	Initial data regarding conditions & replacement of poles will be provided by TPWODL. After award of the contract, BA has to carry out the survey and identify such infra and take necessary action.
34	11KV SOW (Page: 22, Point No: J)	The monthly rent of fuse call camp shall be limited up to Rs. 1500 for rural areas & Rs.2500 for urban areas. (The list of such Fuse Call Centre shall be provided by TPWODL). The same shall be paid to the BA as per approved Rate in RC.	Upon reviewing the Price Bid format, we could not find any separate line item for FCC Rent. Kindly clarify the "How shall the FCC Rent amount be claimed during the contract period?	FCC maintenance shall be the scope of BA only. All the requirement as mentioned in the tender shall be provided by BA without any additional cost.
35	14.1. Special Conditions of Contract (Page No :16, Point No :2)	Price shall remain firm for the entire RC Period. However, TPWODL shall pass on only VDA/ minimum wages revision, made by Govt. of Odisha. The cost of other components shall remain firm throughout the Contract Period.	Kindly clarify whether any changes in VDA and Wage revision shall be borne by TPWODL.	Please refer the clause no 14.1.2 of the tender document.
36	11KV SOW (Page: 10, Point No: XXVII) 11KV SOW (Page: 22, Point No: I)	1. The BA will provide mobile set to all the linemen and TOs posted in their respective area of operation. 2. TPWODL has already provided mobile handsets (WLL) & charger at all BSKs/FCCs, in case of any damage, theft or misplacement of the already existing mobile set or charger, BA shall replace the same (with new mobile set (WLL) & charger equivalent to the earlier existing model) without any additional cost implication to TPWODL.	If all FCC personnel are already equipped with mobile phones, is it mandatory to provide additional mobile phones to all LMs as well? If yes, kindly clarify whether the mobile phones for FCC/LM personnel will be provided by TPWODL or need to be arranged by the BA.	Tender Terms & conditions shall prevail.
37			FRP Ladder up to 7 Mtrs. (Collapsible Ladder)-1 No. per FCC or 1 No. per Section. Kindly confirm	Please refer the revised T & P list as per the RFP/ tender document.
38	Clause No 14.1, Page No 16, Point No 2	Price shall remain firm for the entire RC Period. However, TPWODL shall pass on only VDA/ minimum wages revision, made by Govt. of Odisha. The cost of other components shall remain firm throughout the Contract Period	The cost of other components are also increase on yearly basis, Based on the recent market inflation, cost of tools & plants hiked around 7-10 %. Therefore, We request that a suitable provision for escalation of other cost components based on prevailing inflation indices or mutually agreed terms may also be considered to ensure the sustainable and efficient execution of the contract throughout the contract period.	Tender Terms & conditions shall prevail.
39	Clause No 14.3.2, Page No 23	Payment term for Vehicles & Other Variable line items (Other than 11KV AMC Works / 33KV AMC Works / PSS Operation fixed charges): - 100% payment shall be made within 30 days on submission of the following documents duly certified by EIC/DOS/STS.	100% payment shall be made within 7 days on submission of the error free invoices.	Please refer the below revised Payment terms mentioned in point no 42

FORMAT F.1

Format for Query / Clarification / Deviation (QCD)

Tender No: TPWODL/AK/O/SER/2500001210

Package Name: Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 kV Network Maintenance and Operational Assistance of 33/11 kV Sub-Stations of TPWODL for 3 years.

Note : The said format to be used only for any Pre-bid Query / Clarification/ Deviation on any of the Tender documents

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPWODL Response
1	2	3	4	5
40	General	Tools & Plants	We would like to seek clarification regarding the requirement of double insulated tools in the T&P list for 11KV/33KV AMC & PSS Operation. The cost of these tools is approximately 35%–40% higher than normal tools, and their higher weight also increases handling and maintenance costs, significantly impacting the overall price bid. Further, being the existing contractor in SED and DED divisions, we have already maintained buffer stock of standard tools as per existing requirements. Kindly clarify how the existing inventory will be considered if double insulated tools are made mandatory. We request your kind clarification on the above.	Please refer the revised T & P list as per the RFP/ tender document.
41	General	Qualification and experience certificate of each individual		The Business Associate has to submit attested copies of qualification and experience certificate of each individual with EIC/HOGs/Heads/IR of TPWODL. The declaration of the certificate and experience shall be given on Rs 50 stamp paper. No person with past record of unethical conduct shall be hired/ deployed by Business Associate. TPWODL reserves the right to verify these records and if found any fake certificate than suitable action shall be taken.
42	General	Payment term		Payment term for 11KV AMC Works / 33KV AMC Works / PSS Operation including Vehicle a. BA shall submit monthly error free invoice (s) by 3rd of every month for previous month's bill along with supported documents in Sigitek with soft copy to User team (TPWODL). b. 90% (Gross value) of invoice value shall be released within 7 days of submission of error free certified invoices only in Sigitek portal by BA. c. Balance 10% of the invoices value shall be released within 30 days based on submission of the following documents (verified by EIC/ Divisional Manger): 1. Invoice copy 2. Certified attendance sheet 3. Wage sheets 4. Safety Score card 5. Performance Score Card 6. Tools & Plant Sheets 7. Tripping Data 8. DPR Sheet 9. PSS Cleaning Data (Only of PSS Operations) d. BA will get the invoices verified from the EIC with reference to respective SLA (for Vehicles, separate SLA is there). e. EIC shall check every month with safety department for CSM violations by BA and also check the monthly performance of the BA with respect to performance measurement parameters in SLA. Based on the data & information available, EIC shall prepare performance scorecard indicating deduction of marks for non-compliance and shall forward the same to User (DOS/STS) team. f. Based on EIC feedback on SLA & Statutory Compliances, User (DOS/STS) team will process for release of balance 10% payment. Note: - 1. The performance of BA will be evaluated & validated by EIC- DOS/STS on the basis of MIS/evidences submitted by the BA. Payment of the balance 10% monthly invoice amount will be made as per the marks scored against total 100 marks under various performance criteria in the month. (For example, if the BA has secured 90 marks in the performance measurement, the BA will be paid 90% of the balance 10% monthly invoice amount). 2. In case there is any further applicable deduction owing to CSM violations, same will also be deducted from 10% of the monthly invoice of same month and excess amount, if any, will be deducted from the next month's invoice.

FORMAT F.1**Format for Query / Clarification / Deviation (QCD)**

Tender No: TPWODL/AK/O/SER/2500001210

Package Name: Rate Contract for performance based 11 kV & LT Network Maintenance & Allied Work, 33 kV Network Maintenance and Operational Assistance of 33/11 kV Sub-Stations of TPWODL for 3 years.

Note : The said format to be used only for any Pre-bid Query / Clarification/ Deviation on any of the Tender documents

Sr. No.	Detailed Reference to concerned Document . Please specify Document No / Clause No / Page No	Description as per Bid Document	Query / Clarification / Deviation	TPWODL Response
1	2	3	4	5
				Note- TPWODL reserves the right to deduct and retain an amount equivalent to the gratuity component (excluding GST) of the deployed BA workforce while processing the 10% payment and, which shall be reimbursed upon submission of a valid claim by the BA employee through the respective BA, subject to prevailing statutory provisions. The same shall be ensured by BA cell of TPWODL. 14.3.2 Payment terms other than 11KV AMC Works / 33KV AMC Works / PSS Operation fixed charges 100% payment shall be made within 30 days on submission of the following documents duly certified by EIC/DOS/STS. 1. Error free invoice 2. Work completion certificate (if applicable) 3. Vehicle Logbook Sheet & copy of fitness certificate (if applicable) 4. Attendance sheet (if applicable) 5. Supporting documents (if applicable) If any or all Pt among Pt 2,3 & 4 shall not be applicable, BA shall mention the same in Remarks in the raised invoices.